

Water Sample Lab Report

Method	Test	Result	Limit
660	Colour	<3 mg/l Pt/Co	<20
660	Conductivity	535 µS/cm	<2500
660	pH	7.5	6.5 - 9.5
660	Turbidity	0.168 NTU	<4.0
230	Odour (Qualitative)	None	-
230	Odour (Quantitative)	0	-
230	Taste (Qualitative)	None	-
230	Taste (Quantitative)	0	-
400	E. coli	0 mpn/100ml	0
400	Total Coliforms	0 mpn/100ml	0
430	Colony Count (22°C)	0 cfu/ml	-
730	Aluminium	<6.1 µg/l	<200
730	Iron	<7.3 µg/l	<200
730	Manganese	<1.7 µg/l	<50
255	Ammonium	0.054 mg/l	<0.5
245	Nitrate	2.7 mg/l	<50
225	Nitrite	<0.009 mg/l	<0.5
CALC	Nitrite/Nitrate	0.054	<1.0